



Authorization Certificate of Burning Performance Grade

Certificate No.: Fs2019199

Manufacturer: Jiangsu Hengda Rubber Plastic Co., Ltd.

Address: No. 100, Hengda Road, Jiangsu Hengda Rubber Plastic Co., Ltd., Wuxi, Jiangsu, China

Product Description: NBR Rubber Foam Sheet

Modle No.: Thickness 20 mm

Executive standard: GB 8624-2012 "Classification of burning performance of building materials and products".

The rubber plastic insulation board with the model of 20mm thick produced by your company has been subject to the type inspection of fire safety performance according to GB 8624-2012 classification of combustion performance of building materials and products (inspection report no. 2019101325), and its combustion performance has reached the flame retardant B1 (c-s3, d0, T1) specified in GB 8624-2012. Your company is hereby authorized to use the combustion performance grade mark of this certificate on the above qualified products and packages. Please strictly abide by the relevant provisions on the use of marks.

Issuer:

张翔

Date of issue:

2019年9月23日

Certificate validity:

2022年9月22日

**National Fireproof Building Material Quality
Supervision & Inspection Center**

